



# Economic Value of Supercritical Geothermal Energy in New Zealand

OCTOBER 2023



# Agenda

- GNS' request to Castalia
- What is SCGT: a sustainable, plentiful, and reliable energy source
- SCGT could be available as early as 2037
- SCGT could provide over 2000 MW to the electricity grid by 2050
- SCGT could offer off-grid energy to industry too
- Taking the next steps

# GNS asked us to analyse SCGT's economic potential

Electricity demand is expected to increase by

**50%**

between 2023 and 2050

Industrial energy uses currently served by gas and coal, are ripe for

**DECARBONISATION**

- None of the electricity market models expect much of this demand to be met by new conventional geothermal generation.
- However, GNS, a Government-owned research institute, has identified the potential for drilling deeper into New Zealand's crust in the central north island to access the hotter geothermal resources available there and extract more energy.
- GNS commissioned us to determine what the economic value of this super-critical geothermal (SCGT) resource might be.

# We found that SCGT could be very valuable

SCGT could provide  
**30,000 GWh**  
of sustainable, plentiful, and  
reliable renewable energy to New  
Zealand every year

SCGT could be online by  
**2037**  
if investment occurs and  
regulations are eased

Grid modelling suggests over  
**2,000 MW**  
of SCGT generation could be  
economic to build by 2050

SCGT could also provide  
**ABUNDANT**  
heat and electricity for off-grid  
industrial uses

**SCGT could be  
a sustainable,  
plentiful, and  
reliable energy  
source**



# SCGT offers the same advantages ... at larger scale

## Sustainable



- New developments have made re-injecting 100% of CO<sub>2</sub> extracted during geothermal production possible
- SCGT will use much less land area than other renewables, including conventional geothermal.

## Reliable



- Like conventional geothermal, SCGT is not dependent on external weather conditions
- Existing geothermal is operated approximately 95% of the time.

## Plentiful



- Analysis from GNS suggests that up to **30,000 GWh** of electricity might be available per year from unprotected SCGT resources
- That could supply over 75% of New Zealand's current electricity demand.

# But there is much work to be done

---

GNS has identified three key technical challenges that remain to be solved:



**Refining well construction methods** at SCGT depths so that an adequate commercial well life can be achieved



Determining how to reliably produce SCGT fluids from depth, including the **management of scaling, corrosion and thermal stress issues**



Deciding or **designing the appropriate technology** to use for SCGT power generation, including any fluid processing that might be required in any energy transformation process.

**SCGT could be  
available as  
early as 2037**



# We developed two timelines for SCGT development

---

We developed two cases of when SCGT could be available: baseline and ambitions

Stage	Baseline case	Ambitious case
Scientific and technical progress	2024 to 2038	2024 to 2033
Regulatory approvals	2036 to 2038	2033
Design and construction of the first plant	2039 to 2044	2034 to 2037
<b>Grid synchronization</b>	<b>2045</b>	<b>2037</b>

Our estimates rely on:

- Comparing SCGT's R&D timelines with other technologies, including shale gas and solar PV
- Utilizing data on consenting and construction timelines for clean energy projects in New Zealand and abroad.

# Other energy sources developed quickly

---

## Conventional geothermal

Wairakei was 2<sup>nd</sup> geothermal power station in the world.

Serious consideration in NZ began in 1945. The first power station was commissioned in 1958. Entire station in 1963.

## Shale oil and gas

First US government research begun in 1970s. Barnett Shale gas reserves became economic to tap in 1997.



Shale is now 75% of US natural gas production.

## Solar PV

Initial development was slow: first cells produced in 1954.



But rapid uptake since 2000: solar is now the cheapest energy source in human history in some circumstances.

# We adopted the ambitious timeline for modelling

---

The ambitious timeline better answers questions about the potential value of SCGT to the energy system.



## ENGINEERING CHALLENGES

SCGT energy challenges are mostly engineering solvable with sufficient resources. As opposed to being fundamental scientific issues.




## REGULATORY BARRIERS

In response to the urgent need for decarbonization, Government action can address regulatory barriers (for example, RMA fast-tracking available to hydro, wind, and solar)

# Our ambitious timeline

The timeline below represents Castalia's estimate, informed by GNS and the history of energy research, for the potential duration required for SCGT to become operational if all conditions align.



**SCGT could  
provide over  
2,000 MW to  
the electricity  
grid by 2050**



# Electricity demand will increase by 50% by 2050

---



## ANTICIPATED ELECTRICITY DEMAND SURGE


- Forecasters predict a significant 25-year increase in electricity demand
- Our projections, based on the CCC's demonstration path with a 50% growth by 2050
- The main drivers are electrification of industry and transport, alongside population and economic expansion



## NORTH ISLAND DOMINANCE


- We forecast that two-thirds of this growth will be in the North Island, in line with the current NI share of non-Tiwai electricity use
- This will increase all forms of load: Peak, baseload, and intermediate.
- We assume the North Island load-duration curve will retain the same shape.

# We forecast demand growth across the load profile



# We approximate a Generation Expansion Model


Stage 1: Determine electricity demand



Stage 2: Ascertain options for supply



Stage 3: Determine least cost supply



# The North Island grid will be capacity-constrained

---

## ENERGY AND CAPACITY



## NORTH ISLAND (NI) WINTER CAPACITY MARGIN



## PEAKING ROLE OF VRE



The electricity market must **ensure both energy and capacity** requirements are met. Energy constraints ensure total yearly demand is satisfied, while capacity constraints ensure peak demand can be met at any time

VRE, although cost-effective, are not dependable during peak times. Consequently, Transpower **'de-rates' wind and solar energy** when calculating the North Island (NI) Winter Capacity Margin

Our modelling adopts Transpower's estimates for the peaking role of VRE to determine **the cheapest way to provide sufficient NI capacity** after 2037

# A combination of technologies will be cheapest

We used 'screening curves' to depict various technologies' roles in the future grid

## Screening Curve



Some technologies excel at 'peaking' functions, including gas peakers and short-term energy storage (e.g., batteries)

## Peaking Technologies




Other technologies are proficient at supplying cost-effective energy during capacity-unconstrained periods, such as wind and solar

## Cost-Effective Energy




SCGT's low operating costs and high reliability make it ideal for 'intermediate load' scenarios. In these situations, where wind and solar are less reliable but demand is high, SCGT proves more cost-effective than gas or batteries for meeting demand

## SCGT's Unique Role




# There is a significant role for SCGT– with or without gas

## Generation mix in 2050 when thermals are allowed




## Generation mix in 2050 with a 100% renewables policy




# And this role is robust to higher costs

## SCGT installed capacity in 2050



# SCGT contributes to maintaining energy security

## Peak demand growth is met by peak generation capacity



Values shown are MW of Transpower-rated peak capacity

# Our model may underestimate SCGT's value

---



## MODEL GAP

No hourly dispatch decisions

While the model effectively identifies cost-effective new generation and estimates SCGT capacity based on the North Island load-duration curve changes, it does not determine the System Operator's technology dispatch for hourly electricity demand.



## POTENTIAL OTHER VALUE OF SCGT

Lower electricity prices and higher water levels

With its low 'short-run marginal costs,' SCGT is poised to be dispatched frequently, displacing hydro generation, reducing electricity prices, and supporting higher water levels for long-term storage and renewable energy stability.

**SCGT could  
offer off-grid  
energy to  
industry too**




# There is a sound market for renewable heat

Conventional geothermal is already used in dairy processing and for processing wood products

SCGT could also be used for industrial applications in the central North Island.

This use-case is likely to be co-located with electricity generation, due to the 'tick size' of SCGT being high (say >100MWh per well)

**More than half of industrial energy is still directly sourced from fossil fuels**




MBIE Energy Balance Tables, 2022

# An SCGT-heated mega dairy factory could be viable

- NI dairy factories use approximately **15 PJ** of mostly natural gas energy a year.
- We tested the possibility of supplying one mega-factory with SCGT. Its peak thermal energy demand of ~1500 MW could be satisfied by ~ 15 SCGT wells.
- With our specific assumptions, a dairy heat/electricity co-generating plant of that size earned roughly as much revenue as an electricity-only plant.


## Dairy factory energy demand is inversely correlated with electricity prices



Data from DCANZ and EA for 2022

# SCGT could also be used to dry wood as feedstock

---



# Next steps



## Recommended next steps

Despite the potential benefits of SCGT, government agencies have yet to include it in their analysis. GNS should proactively initiate discussions with MBIE and CCC to explore how SCGT can contribute to addressing the energy trilemma. The objective of engaging with the government is to highlight the potential advantages of SCGT and encourage investments to enhance its technology readiness.

Given that our analysis relies on an assumption that the government prioritises SCGT, including with environmental consents under the Resource Management Act (RMA). GNS should engage with the Ministry of Environment (MoE) to discuss the possibility of adding SCGT to the fast-track consenting process available to hydro, wind and solar.

Government agency		Proposed next step:
MBIE	<a href="#">NZ Energy Strategy</a>	GNS/Next Generation should submit on NZ Energy Strategy by 2 November 2023
	NZ Battery Project	GNS/Next Generation should engage with NZ Battery Project team and highlight the role of SCGT MBIE has suggested already meeting to Castalia
	<a href="#">Gas Transition Plan</a>	GNS/Next Generation should submit short note on Gas Transition Plan noting potential for SCGT in industrial heat by 2 November 2023
	<a href="#">Measures for Transition to an Expanded and Highly Renewable Electricity System</a>	GNS/Next Generation should submit short note by 2 November 2023
CCC	Emissions budget 2026–2030	GNS/Next Generation should seek a meeting with electricity sector experts at CCC to highlight the potential role of SCGT
MoE	The Resource Management Act (RMA)	GNS/Next Generation should seek a meeting with the MoE to consider adding SCGT to the fast-track consenting process

# Recommended next steps

---

Communicate findings to key public sector stakeholders

- MBIE consultations on NZ Energy Strategy, NZ Battery Project
- Climate Change Commission
- Ministry for the Environment.

Engage with key partners

- Mana whenua
- Landowners.

Engage with potential funding partners

- Energy industry
- Geothermal developers.



Andreas Heuser  
Managing Director, Castalia Asia-Pacific  
[andreas.heuser@castalia-advisors.com](mailto:andreas.heuser@castalia-advisors.com)

**Thinking for a better world.**

**WASHINGTON, DC**

1747 Pennsylvania Avenue NW  
Suite 1200  
Washington, DC 20006  
USA

**SYDNEY**

Suite 19.01, Level 19  
227 Elizabeth Street  
Sydney NSW 2000  
Australia

**AUCKLAND**

74D France Street  
Newton South  
Auckland 1010  
New Zealand

**WELLINGTON**

Level 2, 88 The Terrace  
PO Box 10-225  
Wellington 6011  
New Zealand

**PARIS**

3B Rue Taylor  
Paris 75481  
France

**BOGOTÁ**

Calle 81 #11-08  
Piso 5, Oficina 5-121  
Bogotá  
Colombia

# Appendix



# New Zealand's SC generation inventory

Location	Stored heat (exa-joules)	Capacity (MWe)	Generation (GWh/yr)
Kawerau	58	412	3428
S Tikitere	24	169	1408
Haroharo	99	706	5877
SW Reporoa	36	260	2166
W Ohaaki	20	143	1188
W Ngatamariki	21	149	1243
Rotokawa	63	451	3757
Mokai	19	137	1143
Wairakei	19	137	1143
Tauhara	58	412	3428
Tokaanu	38	275	2285
Ngawha	38	275	2285
<b>Total</b>	<b>493</b>	<b>3527</b>	<b>29351</b>

# We evaluate different technologies in different roles

